



Pimpri Chinchwad Municipal Corporation
Pimpri , Pune – 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/1586/2023

Date – 02/02/2023


To,
The Principal,
Dheeraj International School,
Moshi pradhikaran,
Pune 411026

Subject: Water sample Potability Certificate.


Drinking water sample provided by Dheeraj International School, Moshi Pradhikaran Pune 411026, on Date: 30/01/2023 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1582/2023 dated 01/02/2023 & ws /lab /1578/2023 dated 31/01/2023 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.


Chief Chemist
Pimpri Chinchwad Municipal Corporation
Pimpri -18
(प्रशांत जगताप)
चीफकेमिस्ट
जल शुद्धीकरण केंद्र, से. नं. 1
विभाग


MANAGER
DHEERAJ INTERNATIONAL SCHOOL




PRINCIPAL
Dheeraj International School
Pune-411026

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(w/s) DIVISION



No-WS/LAB/1578/2023

Date- 31 / 01 / 2023

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME- Dheeraj International School

DATE OF EXAMINATION-30/ 01 /2023

ADDRESS- Atal Bihari Vajpayee Marg, Moshi Pradhikaran,
Pune.

SOURCE - PCMC Water.


NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coil	
1	Water Sample	Nil.	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

(प्रशांत जगताप)
चीफ केमिस्ट
जल शुद्धीकरण केंद्र, से. नं. 23
पाणीपुरवठा विभाग

CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

MANAGER
DHEERAJ INTERNATIONAL SCHOOL

PRINCIPAL
Dheeraj International School
Pune-411026



NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 1582/2023.

DATE - 01 / 02 / 2023.

DATE OF RECEIPT - 30 / 01 / 2023.

DATE OF EXAMINATION - 01 / 02 / 2023.

NAME - Dheeraj International School.

ADDRESS - Atal Bihari Vajpayee Marg, Moshi
Pradhikaran, Pune.

SOURCE - PCMC Water.

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N.T.U Max	3.39 NTU.	/	
2	pH	6.5 to 8.5	6.87.		
3	Total Hardness (as CaCO ₃)	200 mg/lit	64 mg/lit		
4	Chloride	250 mg/lit	16 mg/lit		
5	Calcium	75 mg/lit	14.42 mg/lit.		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

(प्रशांत जगताप)

चीफकेमिस्ट

जल शुद्धीकरण केंद्र, से. नं. 5

पाणीपुरवठा विभाग

CHIEF CHEMIST

Water treatment plant

sector 23 Nigdi

P. Phorenant

MANAGER

DHEERAJ INTERNATIONAL SCHOOL



Nisha Padmanabhan

PRINCIPAL

Dheeraj International School
Pune-411026